



AECOM 314.429.0100 tel  
1001 Highlands Plaza Drive West 314.429.0462 fax  
Suite 300  
St. Louis, MO 63110-1337  
www.aecom.com

October 7, 2016

Mr. Matt Ballance, PE  
Senior Project Engineer  
Dynergy Inc.  
1500 Eastport Plaza Drive  
Collinsville, Illinois 62234

**RE: Geotechnical Report  
Havana Power Station  
East Ash Pond**

Dear Mr. Ballance:

AECOM is pleased to provide this Geotechnical Report for the Dynergy Midwest Generation, LLC (DMG) East Ash Pond Coal Combustion Residuals (CCR) unit at the Havana Power Station located in Havana, Illinois. This Geotechnical Report has been prepared to document the analyses performed to check that the facility meets the geotechnical slope stability requirements including Factors of Safety required by 40 CFR § 257.73.

AECOM looks forward to providing continued support to Dynergy Midwest Generation, LLC and working together on this important program. Please do not hesitate to call Ron Hager at 314-429-0100 (office) / 440-591-7868 (mobile), if you have any questions or comments on this Geotechnical Report.

Sincerely,

**AECOM**

Brian Linnan, PE  
Site Manager  
[brian.linnan@aecom.com](mailto:brian.linnan@aecom.com)

Ronald Hager  
Program Manager  
[ronald.hager@aecom.com](mailto:ronald.hager@aecom.com)

cc: Mark Rokoff, PE – AECOM

**Attachments:**

- A. Figures
- B. Boring Logs
- C. CPT Data Report
- D. Lab Test Data
- E. Material Characterization Calculations
- F. Static Slope Stability Analysis
- G. Seismic Loading Calculations
- H. Dynamic Response Calculations
- I. Liquefaction Analysis
- J. Seismic Slope Stability Analysis

October 2016

## 1. INTRODUCTION

### 1.1. Purpose of This Report

This report presents the results of the geotechnical analysis prepared by AECOM for the Dynegy Midwest Generation, LLC (DMG<sup>1</sup>) Coal Combustion Residuals (CCR) East Ash Pond unit at the Havana Power Station, located in Havana, Illinois (see **Attachment A** for Site Location Map, **Figure 1**). The purpose of the geotechnical investigation and analyses performed is to evaluate the design, performance, and condition of the impoundment and associated structures using the data collected from surface and subsurface investigations, available design drawings, construction records, inspection reports, previous engineering investigations, and other pertinent historic documents provided to AECOM by DMG. This information was then used to evaluate the design and operation of the surface impoundment against the regulatory standards set in 40 CFR § 257.73.

The geotechnical field evaluation was conducted between August 21 and September 22, 2015. The field program consisted of conventional hollow stem auger (HSA) and mud rotary borings, Standard Penetration Testing (SPT), obtaining undisturbed samples of subsurface soils, and Cone Penetration Testing (CPT). Laboratory testing was conducted on the materials obtained through various sampling techniques to assist in characterization of the subsurface conditions, especially with respect to defining material parameters for use in stability analyses. Stability analyses were performed by AECOM to evaluate the potential for slope instabilities, in accordance with the Environmental Protection Agency (EPA) regulation 40 CFR 257.73(d) and (e).

A summary of the geotechnical field program, laboratory testing program, and stability evaluations are presented herein. Detailed interpretations, calculations, and presentation of analysis results are provided in the Attachments to this report.

### 1.2. Description of Impoundments

The Havana Power Station is located on the east bank of the Illinois River, as shown in **Figure 1** of **Attachment A**. The East Ash Pond is located on the Illinois River floodplain east of the power plant and is approximately 1,500 feet east of the river. The East Ash Pond is comprised of four (4) individual cell units (Cells 1 through 4) surrounded by a common exterior dike, with a total area of approximately 99 acres. Cell 1 and Cell 4 have 3-foot thick clay liners and Cells 1 and 2 have a composite liner consisting of 1 foot of clay overlain by a 45-mil polypropylene geomembrane. Cell 1 and Cell 4 have crest elevations ranging from 488 to 490 feet (all elevations in this report are listed in the NAVD88 datum, unless otherwise stated), with maximum embankment heights of 22 feet and 26 feet, respectively. The crest elevation for Cell 2 ranges from 488 to 490 feet and from 494 to 496 feet for Cell 3, with maximum embankment heights of approximately 35 feet and 31 feet, respectively. The typical crest width is 15 feet. Upstream and downstream slopes were constructed at 3 horizontal: 1 vertical (3H:1V).

---

<sup>1</sup> Although the Havana Power Station and the East Ash Pond are owned and operated by DMG, Dynegy Administrative Services Company (*Dynegy*) contracted AECOM to develop this geotechnical report on behalf of DMG. Therefore, "Dynegy" is referenced in materials attached to this geotechnical report.

## 2. SUMMARY OF FIELD INVESTIGATIONS

The subsurface exploration performed for the East Ash Pond included 11 auger borings and 8 cone penetration test (CPT) soundings with seismic shear wave velocity measurements and pore pressure dissipation (PPD) testing. The locations of the borings and CPT soundings are shown in **Figure 2 of Attachment A**. The borings were drilled by AECOM's subcontractor Frontz Drilling of Wooster, Ohio. Frontz Drilling used an all-terrain CME-750 drill rig in conjunction with 3¼-inch inner diameter hollow stem augers to drill the borings. Three borings; HAV-EB-1T, HAV-EB-2T, and HAV-EB-5T; were drilled at the toe of the embankment. The "T" following the boring number designates that the boring was drilled at the toe of the embankment. The crest borings are designated with a "C". Eight borings were drilled on the crest; HAV-EB-1C through HAV-EB-8C.

Borings at the toe of the embankment were drilled to depths ranging between 40 and 42.5 feet below ground surface (bgs). Borings drilled on the crest of the embankment were drilled to depths ranging between 40 and 62.5 feet below the embankment crest. All borings were terminated in alluvial soils and were not extended to bedrock. Undisturbed samples of subsurface materials were obtained using thin-walled Shelby tubes advanced in accordance with ASTM D1587. Disturbed samples were obtained with a split spoon sampler in accordance with ASTM D1586 (Standard Penetration Test – SPT). Boring logs are included in **Attachment B**.

CPT soundings were performed by AECOM's subcontractor ConeTec, Inc, of Charles City, Virginia. CPT soundings conducted at the toe of the embankment extended to depths ranging between 40 and 45.1 feet bgs. CPT soundings on the embankment crest extend to a depth of 85.5 feet below the embankment crest. All CPTs were terminated in alluvial soils and were not extended to bedrock. In-situ measurements such as tip resistance, sleeve resistance, and dynamic pore pressure were continuously recorded as the cone was advanced into the ground. Seismic shear wave measurements (SCPTu) were generally taken at 1 meter (3.3 feet) intervals and PPD tests were taken at selected intervals once the tip advanced into saturated materials. A complete report prepared by ConeTec that includes the graphical CPT logs and the results of the SCPTu and PPD tests is included in **Attachment C**.

**Table 1** lists pertinent information regarding the auger borings and CPT soundings.

**Table 1 - Exploratory Boring and CPT Summary**

<b>Boring or CPT Designation</b>	<b>Surface Elevation<sup>(2)</sup> (ft NAVD88)</b>	<b>Northing<sup>(2)</sup> (ft NAD83)</b>	<b>Easting<sup>(2)</sup> (ft NAD83)</b>	<b>Boring or Sounding Depth (ft)</b>
<b>CPT Soundings</b>				
HAV-C001	470.0	1315557	2323963	40.0
HAV-C002	476.8	1317122	2324639	40.0
HAV-C003	466.2	1317190	2323758	45.0
HAV-C004	465 <sup>(4)</sup>	1316558 <sup>(4)</sup>	2323308 <sup>(4)</sup>	40.0
HAV-C005	462.4	1316130	2322125	40.0
HAV-C006	467.5	1315507	2321893	45.1
HAV-C007	489.3 <sup>(5)</sup>	1315619 <sup>(5)</sup>	2322377 <sup>(5)</sup>	85.5
HAV-C008	488.8 <sup>(5)</sup>	1315277 <sup>(5)</sup>	2322411 <sup>(5)</sup>	85.5
<b>Auger Borings</b>				
HAV-EB-1C <sup>(1)</sup>	495.6	1315651	2323895	61.5
HAV-EB-1T <sup>(1)</sup>	470.0 <sup>(3)</sup>	1315557 <sup>(3)</sup>	2323963 <sup>(3)</sup>	40.0
HAV-EB-2C	495.9	1317140	2324566	56.0
HAV-EB-2T	476.8 <sup>(3)</sup>	1317122 <sup>(3)</sup>	2324639 <sup>(3)</sup>	42.5
HAV-EB-3C	495.7	1317143	2323860	61.5
HAV-EB-4C	495.4	1316468	2323339	40.0
HAV-EB-5C	490.1	1316096	2322227	62.5
HAV-EB-5T	462.4 <sup>(3)</sup>	1316130 <sup>(3)</sup>	2322125 <sup>(3)</sup>	40.0
HAV-EB-6C	488.8	1315472	2322011	40.0
HAV-EB-7C	489.3	1315619	2322377	42.5
HAV-EB-8C	488.9	1315277	2322411	40.0

**Notes:**

- (1) C and T refer to Crest and Toe locations on the embankment.
- (2) The boring and CPT elevations and locations were surveyed by Weaver Consultants and provided to AECOM by DMG.
- (3) Toe borings not surveyed, surveyors unable to find boring location; assumed to be the same as CPT borings at respective locations.
- (4) Not surveyed, surveyors unable to find boring location; northing/easting and elevation are approximate.
- (5) HAV-C007 and C008 not surveyed, no evidence of boring; assumed to have same elevation and northing/easting as HAV-EB-7C and 8C.

### 3. SUMMARY OF SITE-SPECIFIC SUBSURFACE CONDITIONS

The subsurface profile over the site included embankment fill materials and native alluvial sand. Fine-grained (clayey) soils were not encountered in significant quantities within the alluvium at the boring locations. Four representative material horizons were identified and are briefly described below with Unified Soil Classification System (USCS) designations where available.

**Embankment Fill:** The East Ash Pond embankments consist of poorly graded sand, poorly graded sand with silt, and silty sand. Based on uncorrected SPT N-values, the embankment materials are well compacted for the majority of the embankment, ranging from medium dense to very dense. Zones of loose sand were encountered at boring HAV-EB-6C from 7 feet to 12 feet bgs and in boring HAV-EB-7C from 10 feet to 25 feet bgs. Fines content (the material passing the number 200 sieve), typically ranged between 5% and 25% with an average of 13%, indicating clean to silty sands. A clayey sand (SC) was encountered between depths of 0 and 7 feet bgs in boring HAV-EB-6C. Boring HAV-EB-6C encountered a layer of silty sand (SM) with a fines content of 35% at a

depth of 10 feet below the embankment crest. A 0.5-foot thick layer of sandy lean clay (CL) was encountered between a depth of 4 and 5 feet at Boring HAV-EB-8C. These were the only fine-grained soils encountered in the embankment fill boring locations.

Clay Liner: Samples of the clay liner were not collected in order to avoid puncturing the liner system. Consequently, conservative soil properties were assigned based on AECOM's experience.

Fly Ash: CCR materials were not encountered in the embankment fill during this exploration, and borings or CPTs were not advanced through the retained CCRs due to the risk of puncturing the liner system. Consequently, conservative engineering properties were assigned based on AECOM's experience.

Native Alluvial Foundation: The native alluvial materials typically consisted of poorly graded sand and sand with silt. The native material begins at elevations ranging between approximately 463 and 470 feet at the boring locations. Measured densities from corrected SPT N-values ranged between very loose and medium dense. Fines content was typically lower than the embankment fill and ranged between 1% and 30% with an average of 5%. A clayey sand (SC) layer was encountered between depths of 9 feet and 12 feet bgs in Boring HAV-EB-2T and a silty, clayey sand (SC-SM) was encountered between 27 and 32 feet bgs in Boring HAV-EB-6C. No other zones of relatively high fines content material were encountered.

**Tables 2 and 3** summarize the uncorrected SPT N-values and the uncorrected CPT tip resistance values in tons per square foot (tsf) for the embankment fill and native alluvial foundation materials. The N-values shown were taken as the number of blows per foot (bpf) for the last 12 inches of SPT sampler advancement. Complete results of the boring and CPT logs are included in **Attachments B and C**, respectively.

**Table 2 - Embankment Fill Field Measurement Summary**

Category	Minimum	Maximum	Average
SPT N-values (bpf)	6	66	32
Cone Resistance, $q_c$ (tsf)	2	544	221
Sleeve Resistance, $f$ (tsf)	0.0	6.2	2.2
Friction Ratio, $R_f$ (%)	0.0	4.3	1.2
SCPTu Shear Wave Velocity (ft/sec)	515	869	709

**Table 3 - Native Alluvial Foundation Field Measurement Summary**

Category	Minimum	Maximum	Average
SPT N-values (bpf)	4	34	11
Cone Resistance, $q_c$ (tsf)	2	446	137
Sleeve Resistance, $f$ (tsf)	0.0	5.4	0.7
Friction Ratio, $R_f$ (%)	0.1	3.9	0.6
SCPTu Shear Wave Velocity (ft/sec)	407	1206	789

### 3.1. Phreatic Water Conditions

Phreatic conditions within the foundation soils were evaluated using the nine existing monitoring wells present in the area of the East Ash Pond. Phreatic levels in these wells were measured by Natural Resource Technology (NRT) in November 2015. Data from the November 2015 measurements, which reasonably agreed with phreatic conditions measured during the CPT investigation, was used by AECOM to develop piezometric conditions for use in the stability analyses. Based on borings advanced through the embankments, the embankment soils are unsaturated due to the presence of the liner system.

## 4. SUMMARY OF LABORATORY TESTING

Soil samples collected from the exploratory borings were sealed at the site and transported to the AECOM Overland Park, Kansas office, where a geotechnical engineer visually examined the samples and selected samples for laboratory testing. The selected soil samples were then sent to Alpha Omega Geotech's Kansas City, Kansas office for testing. The sections below summarize the number of tests performed and results of the soil testing

### 4.1. Summary of Laboratory Testing Scope

A total of 81 samples were tested using ASTM D422, Standard Test Methods for Particle Size Analysis of Soils, and ASTM D1140, Standard Test Methods for Amount of Material in Soils Finer than No. 200 Sieve, where appropriate. The classification tests included 35 tests for the embankment fill and 46 tests for the native alluvial foundation materials. In addition to the classification tests, ASTM D2216, Test Method for Laboratorial Determination of Water Content, and ASTM D4318, Test Method for Liquid Limit, Plastic Limit and Plasticity Index, were also performed for selected samples.

### 4.2. Summary of Laboratory Testing Results

A brief summary of the laboratory testing results for water content, fines content and the Atterberg Limits is provided below in **Table 4** and **Table 5**. The isolated clay layers were omitted from the fines content averages listed below. The gradation curves and complete summary of the laboratory data are included in **Attachment D**.

**Table 4 - Summary of Moisture and Fines Contents**

Material	Water Content			Fines Content		
	Minimum	Maximum	Mean	Minimum	Maximum	Mean
Embankment Fill	4.6	17.4	8.8	4.6	61	13
Native Alluvial Foundation	-	-	-	0.8	38	9

**Table 5 - Summary of Atterberg Limits**

Boring Designation	Depth of Sample (feet bgs)	Liquid Limit	Plastic Limit	Plasticity Index
HAV-EB-1C	26-27.5	Non-plastic		
HAV-EB-2C	3.5-5	Non-plastic		
HAV-EB-3C	11-12.5	Non-plastic		
HAV-EB-4C	33.5-34	14	13	1
HAV-EB-6C	3.5-5	25	14	11
HAV-EB-6C	8.5-10	14	13	1
HAV-EB-6C	28.5-30	18	13	5
HAV-EB-8C	3.5-5	30	15	15

## 5. SLOPE STABILITY ANALYSES

Slope stability analyses were performed for varying loading conditions at three cross-sections: A, B, and C. Cross section locations are shown in **Figure 2** of **Attachment A**. Surface topography, subsurface stratigraphy and soil parameters were established from the results of the site geotechnical exploration and pertinent historic data. A discussion of the selection of the cross sections and soil properties used for the stability analysis are presented in the following sub-sections.

### 5.1. Cross-Sections for Analysis

Three cross-sections, identified as Cross Sections A, B, and C in **Figure 2** of **Attachment A**, were selected for stability analysis. The sections were selected to analyze representative areas of embankment stability in regards to embankment height, slope orientation, and subsurface conditions. Cross section C was selected for analysis because the embankment is the highest (35 feet) at this location, and a layer of weaker material is present at the embankment/foundation interface. Sections A and B were selected for analysis because liquefaction-susceptible materials are present in the foundation at these sections. While liquefaction-susceptible materials were also found to be present in other portions of the foundation where an analysis cross-section is not present, the thickness of the liquefaction-susceptible materials as well as the height of the embankment were less than observed at Sections A and B, and additional sections were therefore not analyzed as the post-liquefaction factors of safety would be higher than at Sections A and B, by inspection.

**Table 6 - Geotechnical Explorations at Cross Sectional Locations**

Cross Section	Geotechnical Subsurface Data Used in Cross-Section
A	HAV-EB-3C and HAV-C003
B	HAV-EB-1T, HAV-EB-1C, HAV-C001
C	HAV-EB-5T, HAV-EB-5C, HAV-C005

The topography for the cross sections was taken from the 2015 ground and bathymetric survey prepared by Weaver Consultants Group in November 2015. Original ground surfaces and pond bottom elevations were estimated using the 2015 survey and design drawings provided by DMG. The borings and CPT soundings used to construct the cross sections are shown in **Table 6**.

## 5.2. Stability Analysis Conditions Considered

Consistent with the criteria provided in the USEPA CCR Rule § 257.73(e), the stability of the East Ash Pond embankment was evaluated for four load cases

**Static, Long-Term Maximum Storage Pool Condition:** This case models the conditions under static, long-term conditions, under the maximum storage water level within the impoundment. Water elevations used for analysis were 486.0, 485.0, 492.0 and 484.5 feet for Cells 1, 2, 3, and 4, respectively, as listed in AECOM's hydrologic and hydraulic report (AECOM, 2016) for the East Ash Pond. Drained (effective stress) shear strength parameters were used for all materials. The phreatic conditions were estimated based on water level readings in nearby wells made by NRT in November 2015. **Target Factor of Safety = 1.50.**

**Static, Maximum Surge Pool Condition:** This case models the conditions under a short-term surcharge elevation of 487.1, 486.8, 492.9 and 486.7 feet for Cells 1, 2, 3, and 4, respectively, as listed in AECOM's hydrologic and hydraulic report (AECOM, 2016) for the East Ash Pond. Drained strengths were used for the analysis, as the material comprising the embankment and foundation are primarily free-draining and granular and thus are expected to behave in a drained manner during surcharge pool loading. Phreatic conditions within the embankment and foundations were assumed to be the same as the maximum storage pool condition due to the presence of a liner system in the East Ash Pond. **Target Factor of Safety = 1.40.**

**Seismic Slope Stability Analysis:** These analyses incorporate a horizontal seismic coefficient ( $k_h$ ) selected to be representative of expected loading during the 2,500-yr return period design earthquake event (i.e., a "pseudostatic" analysis). The analyses utilized drained strengths because the soils are free-draining and granular and thus are expected to behave in a drained manner during seismic loading. The same pool level and phreatic conditions as the maximum storage pool condition case were used for this analysis. **Target Factor of Safety = 1.00**

**Post-Liquefaction Condition:** Liquefaction triggering analyses (see **Section 5.3.2.3**) identified the presence of soils susceptible to liquefaction within the foundation of the East Ash Pond. The triggering analysis did not identify any soils susceptible to liquefaction within the East Ash Pond dikes. Therefore, a post-earthquake (i.e. liquefaction) slope stability analysis is not required per §257.73(e), as the dikes soils are not susceptible to liquefaction). However, a post-earthquake slope stability analysis was performed to evaluate the effects of liquefaction in the foundation at the East Ash Pond, in order to support the evaluation of foundation stability, per §257.73(d)(1)(i). The target factor of safety for post-earthquake analysis listed in §257.73(e) of 1.20 was also used as the target factor of safety for this analysis, as §257.73(d)(1)(i) does not specify a minimum factor of safety for post-earthquake slope stability analysis. No horizontal seismic coefficient is included in these analyses. Sluiced CCRs retained by the dikes were assumed to liquefy for this analysis, although the material is not located within the dikes themselves or with the foundation. These analyses were performed at stability cross sections A and B because liquefaction triggering analyses found liquefaction-susceptible soils within the foundation soils at these locations. Liquefaction-susceptible soils were not found at cross section C. The same pool level and phreatic conditions as the maximum storage pool condition case were used for this analysis. **Target Factor of Safety = 1.20.**



### 5.3. Methodology of Analyses

Limit equilibrium slope stability analyses were performed using the computer software program SLOPE/W 2012 v.8 from GeoStudio International. Factors of safety were calculated using Spencer's method and using both circular and wedge search routines to evaluate the failure surface for each analysis section and load case because this method satisfies both moment and force equilibrium. Critical surfaces were considered to be those which intersected the embankment crest and could result in a release of CCR materials. Pore pressures were assigned as hydrostatic pressure under the piezometric line.

The following sections briefly summarize the analysis and soil parameters used for the static, seismic, and post-liquefaction conditions. Detailed presentation of the analyses are provided in **Attachment F** for static slope stability analysis and **Attachments G, H, and I** for development of ground motions and liquefaction triggering analyses for the earthquake loading conditions. Seismic slope stability results are contained in **Attachment J**.

#### 5.3.1. *Static Analysis Conditions*

The strength parameters for static analysis conditions are listed in **Table 7**.

**Table 7 - Static Material Properties for Stability Analysis**

Material	Total Unit Weight(pcf)	Effective (drained) Shear Strength Parameters	
		c' (psf)	$\Phi'$ (°)
Embankment Fill	120	0	40
Lower Strength Embankment	120	0	30
Clay Liner	110	50	29
Fly Ash	90	0	20
Native Alluvial Foundation	115	0	30

The primary shear strength parameter for cohesionless soils is the effective internal friction angle,  $\phi'$  ( $f'$ ). This was developed using the corrected N-values from the SPT and correlating them with the effective stress at each SPT location using a chart from Coduto, 2012. Data and calculation spreadsheets provided by ConeTec show that the CPT data was correlated to  $f'$  using Kulhawy and Mayne (1990).

The lower SPT N-values near the embankment/foundation interface at borings HAV-EB-2C and HAV-EB-3C were accounted for in Section A stability analysis. The inclusion of this layer was considered to be conservative because the depths at which the SPTs were taken were likely part of the foundation but no further evidence allowed for the layer to be discounted.

Further details regarding the calculations of the shear strength parameters are presented in **Attachment E**.

### **5.3.2. Earthquake Analysis Conditions**

Published seismic data from the United States Geological Survey (USGS) for the area of the Havana East Ash Pond were referenced to obtain the parameters needed for a liquefaction analysis and to analyze the seismic loading condition. The procedures used are described below.

#### **5.3.2.1. Seismic Loading**

Seismic loading was evaluated using the USGS 2008 online Probabilistic Seismic Hazard Deaggregation tool in order to determine the Peak Ground Acceleration (PGA) at top-of-rock with an exceedance probability of 2% in 50 years. This resulted in a PGA-rock of 0.072g, with the greatest contribution to hazard coming from an earthquake with mean moment magnitude ( $M_w$ ) = 6.95 at a distance of 246 km. Refer to **Attachment G** for more information on the Seismic Loading.

#### **5.3.2.2. Dynamic Response Analysis**

The USGS 2008 Deaggregation Tool was used to provide a simplified estimate of the site's dynamic responses. The tool provides for PGA on rock as input to calculate the dynamic response of the foundation soil using International Building Code (IBC) and National Earthquake Hazards Reduction Program (NEHRP) information or procedures. The East Ash Pond foundation was first classified as a stiff soil profile, site Class D, based on the shear wave velocity ( $V_s$ ) measurements obtained from the CPT soundings. This resulted in an amplification of the PGA-rock = 0.072 g to PGA-design = 0.12 g.

The design acceleration was converted from a peak transverse base acceleration to a peak transverse crest acceleration, using a correlation provided by Idriss (2015). The maximum crest acceleration was calculated to be 0.33 g. The PGA was converted to an equivalent horizontal force ( $k_h$ ) that was used as input into the programs for seismic analysis using Makdisi-Seed procedure (1978). **Attachment G** includes a more detailed description of the processes and methods used to obtain the final  $k_h = 0.11$  g value.

#### **5.3.2.3. Liquefaction Triggering Analysis**

The potential for liquefaction was evaluated using a liquefaction triggering analysis based on the SPT and CPT data. The analysis was conducted by using the Idriss and Boulanger (2008) procedure. The SPT- and CPT-based triggering analyses use the stress-based framework of the Cyclic Resistance Ratio (CRR) and the Cyclic Stress Ratio (CSR) parameters. The CRR is an empirical correlation between N-values or  $q_c$ -values, corrected for overburden and fines content. The CSR is likewise an empirical function of PGA and is corrected for magnitude and overburden stress. The fines content for the CPT-based analysis was developed from relationships using the Soil Behavior Type Index reported on the ConeTec CPT logs in **Attachment C**. These were compared with the lab data in **Attachment D** at the appropriate depths. The lab data was used solely in the SPT-based correlation for fines. The SPT and CPT triggering results for the loose layers were typically in good agreement. The complete liquefaction analysis is in **Attachment I**.

#### **5.3.2.4. Strength Parameter Selection**

Post-liquefaction slope stability analyses were performed at Sections A and B, where liquefaction-susceptible soils were found in the foundation. The shear strength for the liquefaction-susceptible portions of the native alluvial foundation, as well as the sluiced ash retained in the East Ash Pond, is shown in **Table 8**. The shear strengths were selected using published correlations in Idriss and

Boulanger (2008). Material strengths for materials not susceptible to liquefaction were assumed to be the same as those presented in **Table 7**, as the soils not susceptible to liquefaction are granular and free-draining, and are therefore assumed to behave in a drained manner during post-earthquake loading. Refer to **Attachment E** for the complete material strength characterization used in the seismic analysis.

**Table 8 - Seismic Material Properties for Stability Analysis**

Material	Total Unit Weight (pcf)	Shear/Normal Stress Ratio
Liquefied Foundation Layer	115	0.06
Fly Ash-Liquefied	90	0.05

## 6. RESULTS

### 6.1. Results of Static Analyses

The results of the limit equilibrium slope stability analyses for the static load cases are summarized in **Table 9** below. The output figures showing the slip surfaces and details of the analyses are included in **Attachment F**.

**Table 9 – Static Analysis Results**

Loading Condition	Program Criteria	A	B	C
Steady State (Normal Pool)	FS $\geq$ 1.50	2.23	2.47	2.10
Steady State (Flood Pool)	FS $\geq$ 1.40	2.23	2.47	2.10

### 6.2. Results of Earthquake Analyses

#### 6.2.1. Liquefaction Triggering Analysis

Liquefaction-susceptible soils were not identified within the dikes at the East Ash Pond, as the dikes are unsaturated and well-compacted. The native alluvial foundation material was found to be susceptible to liquefaction in limited, relatively thin loose layers at depths of 17 to 31 feet below the toe of the embankment. Section B had the thickest layer of liquefiable material, ranging from approximately elevation 446 feet to elevation 439 feet (depth 24 feet to 31 feet), based on CPT and SPT data. Section A had a thinner layer of liquefiable material based on CPT data that ranged approximately from elevation 448.1 feet to 442.5 feet (depth 17.1 feet to 22.5 feet). The liquefaction analysis identified thin (e.g. 1 foot or less), isolated zones of potentially-liquefiable material at other locations in the foundation, however these zones are not assumed to represent a laterally or vertically-continuous layer as they are spatially disconnected. The sluiced fly ash retained by the embankment is also assumed to be susceptible to liquefaction, due to its wet-sluiced nature. All other soils within the embankment and foundation were not found to be susceptible to liquefaction during the design seismic event. Details of the liquefaction analysis can be found in **Attachment I**.

### 6.2.2. Earthquake Analysis Conditions

The results of the slope stability analyses for the seismic load cases are summarized in **Table 10**. The output figures showing the slip surfaces and details of the analyses are included in **Attachment J**. It should be noted that a post-liquefaction analysis was not performed at Section C as neither the embankment or foundation soils at Section C are susceptible to liquefaction.

**Table 10 – Seismic Analysis Results**

Loading Condition	Program Criteria	A	B	C
Seismic Pseudo-Static (Normal Pool)	FS $\geq$ 1.00	1.64	1.76	1.51
Post-Earthquake Liquefaction (Normal Pool)	FS $\geq$ 1.20	1.31	1.78	N/A

## 7. CONCLUSIONS

The calculated factors of safety from the limit equilibrium slope stability analyses satisfy the USEPA CCR Rule §257.73(e) requirements for all the load cases analyzed at the cross sections for the embankment that comprise the perimeter of the Havana East Ash Pond. Load cases analyzed for this study include static (steady-state) maximum storage pool, maximum flood surcharge pool, seismic (pseudo-static), and static post-liquefaction.

## 8. LIMITATIONS

Background information, design basis, and other data have been furnished to AECOM by DMG, which AECOM has used in preparing this report. AECOM has relied on this information as furnished, and is not responsible for the accuracy of this information. Our recommendations are based on available information from previous and current investigations. These recommendations may be updated as future investigations are performed.

Borings have been spaced as closely as economically feasible, but variations in soil properties between borings, that may become evident at a later date, are possible. The recommendations made in this report are based on the assumption that the subsurface soil, rock, and phreatic conditions do not deviate appreciably from those disclosed in the site-specific exploratory borings. If any variations or undesirable conditions are encountered in any future exploration, we should be notified so that additional recommendations can be made, if necessary.

The conclusions presented in this report are intended only for the purpose, site location, and project indicated. The recommendations presented in this report should not be used for other projects or purposes. Conclusions or recommendations made from these data by others are their responsibility. The conclusions and recommendations are based on AECOM's understanding of current plant operations, maintenance, storm water handling, and ash handling procedures at the station, as provided by DMG. Changes in any of these operations or procedures may invalidate the findings in this report until AECOM has had the opportunity to review the changes, and revise the report if necessary.

This geotechnical investigation was performed in accordance with the standard of care commonly used as state-of-practice in our profession. Specifically, our services have been performed in accordance with accepted principles and practices of the geological and geotechnical engineering

profession. The conclusions presented in this report are professional opinions based on the indicated project criteria and data available at the time this report was prepared. Our services were provided in a manner consistent with the level of care and skill ordinarily exercised by other professional consultants under similar circumstances. No other representation is intended.

## 9. REFERENCES


- AECOM (2016). *Hydrologic and Hydraulic Summary Report, Havana Power Station, East Ash Pond*.
- Conetec, (2015). *Calculated CPT Geotechnical Parameters A Detailed Description of the Methods Used in ConeTec's CPT Geotechnical Parameter Calculation and Plotting Software, Revision 7*. Provided to AECOM by ConeTec.
- Coduto, D., (2012). *Foundation Design Principles and Practices, 2<sup>nd</sup> Ed.*, Pearson, New York, NY.
- Boulanger, R. W., and Idriss, I. M., (2014). *CPT and SPT Based Liquefaction Triggering Procedures (Report No. UCD/CGM-14/01)*. Davis, California.
- Dynegy,(1991). *Design Drawings: E-HAV-C17, E-HAV-C113, and E-HAV-C167*
- GEO-SLOPE International Ltd. (2015). "GeoStudio 2012 (SLOPE/W and SEEP/W)." Calgary, Alberta, Canada.
- Idriss, I. M., and Boulanger, R. W., (2008). *Soil Liquefaction During Earthquakes*. Earthquake Engineering Research Institute, Oakland, California, USA.
- International Code Council, (2003). *2003 International Building Code*.
- Makdisi, F. I., and Seed, H. B., (1978). "A Simplified Procedure for Estimating Dam and Embankment Earthquake-Induced Deformations." *Journal of the Geotechnical Engineering Division*, 104(7), 849–867.
- Natural Resource Technology, (2015). *Groundwater Monitoring Report, Havana Generating Station*.
- NEHRP (National Earthquake Hazards Reduction Program), (2009). *Recommended Seismic Provisions for New and Other Structures*, (FEMA P-750), 2009 Edition.
- Seed, R.B., et al, (2003). *Recent Advances in Soil Liquefaction Engineering: A Unified And Consistent Framework*, 26th Annual ASCE Los Angeles Geotechnical Spring Seminar, Keynote Presentation, H.M.S. Queen Mary, Long Beach, California, April 30, 2003.
- U.S. Environmental Protection Agency [USEPA]., (2015). *Standards for the Disposal of Coal Combustion Residuals in Landfills and Surface Impoundments*. 40 CFR §257. Federal Register 80, Subpart D, April 17, 2015.
- USGS "2008 Interactive Deaggregations." (2008). 2008 Interactive Deaggregations, <<http://geohazards.usgs.gov/deaggint/2008/>> (Feb. 22, 2016).

## ATTACHMENT A

---

FIGURES







**LOCATION MAP**  
 NOT TO SCALE



**VICINITY MAP**  
 NOT TO SCALE


 8300 College Boulevard, Suite 200 Overland Park, Kansas 66210		
CLIENT: DYNEGY MIDWEST GROUP, INC.		
LOCATION: HAVANA, IL		
TITLE: <b>LOCATION MAP &amp; SITE VICINITY MAP</b>		
DRAWN BY SMS	CHECKED BY BDL	APPROVED BY BDL
PROJECT NO. 60439304	DATE FEB. 2016	FIGURE NO. 1







**LEGEND:**

HAV-EP-5T  
 APPROXIMATE LOCATION FOR PROPOSED EXPLORATORY BORING LOCATION

HAV-C003  
 CPT LOCATION AND NUMBER

 SLOPE STABILITY CROSS SECTION NUMBER AND LOCATION



SOURCE: GOOGLE EARTH PRO IMAGE

DYNEGY MIDWEST GENERATION, LLC  
 HAVANA, IL

PROJECT NO.  
 60439304



DRN. BY:djd September 2016  
 DSGN. BY:bt  
 CHKD. BY:lc

Havana East Ash Pond Exploratory  
 Boring Locations, CPT Locations, &  
 Cross Sections for Stability Analysis

FIG. NO.  
 2



## ATTACHMENT B

---

BORING LOGS

The exploratory borings for Havana Station East Ash Pond were drilled between August 31 and September 4, 2015. AECOM subcontracted with Frontz Drilling to drill a total of 11 exploratory borings. Borings drilled on the crest of the embankment included HAV-EB-1C through HAV-EB-8C, while toe borings included HAV-EB-1T, HAV-EB-2T, and HAV-EB-5T. The locations of the exploratory borings are shown in Figure 1.

All of the exploratory borings were drilled by Frontz Drilling using an all-terrain Central Mine Equipment (CME-750) drill rig. The borings were advanced using hollow stem augers. Borings on the crest of the embankment were drilled to termination depths ranging between approximately 40 and 62.5 feet below ground surface (bgs), while borings at the toe of embankment were drilled to depths ranging between approximately 40 and 42.5 feet bgs. All borings were backfilled with cement-bentonite grout upon completion.

Relatively undisturbed samples of subsurface materials were obtained using thin-walled Shelby tubes that were advanced with a standard Shelby tube head in general accordance with ASTM D1587. The push length of the thin-walled tubes was approximately 18 inches. Disturbed samples were obtained with a split barrel sampler in general accordance with ASTM D1586 (Standard Penetration Test – SPT).







































































Recovered soil samples were initially identified and field logged by a geologist by observing the drilling characteristics, cuttings, and soil samples. All soil samples were transported to the AECOM laboratory in Overland Park, Kansas for designation of testing. Selected samples were sent to the Alpha-Omega laboratory located in Kansas City, Kansas. The field boring logs were revised based on review of the laboratory test results.

The final boring logs presented in this appendix were generated using gINT geotechnical software by Bentley Systems. The gINT software tools utilize a geotechnical database and graphics package to present various geotechnical outputs (i.e., boring logs, test summaries, etc.). The gINT logs herein show the soil classification in accordance with Unified Soil Classification System (USCS), sampler type, sample depths, recovery, resistance, and drilling method, as well as laboratory testing data such as moisture content, dry unit weight, Atterberg limits, and unconfined compression. The descriptions used to describe the consistency on the final logs are based on the strengths obtained by field testing.

## BORING LOG NOMENCLATURE SHEET

TERM	IDENTIFICATION AND DESCRIPTION			
SPT	Split-Spoon Sample (Standard Penetration Test): A 2-inch O.D., 1.5-inch I.D., split-barrel, 18 to 30-inch long sampler is driven by blows from a 140-pound hammer falling 30-inches. The number of blows required to advance the sampler three 6-inch increments are counted (See Sampling resistance below).	The relative density of coarse-grained soils (sands and gravels having less than 50 percent passing the number 200 sieve) is indicated by the uncorrected SPT test result (N-Value or blow count) in accordance with the relationships given below:		
		<b>RELATIVE DENSITY</b>	<b>BLOW COUNT (N-VALUE)</b>	
		Very Loose	0 to 4	
		Loose	5 to 10	
		Medium Dense	11 to 30	
C	California Sample: Thick-wall sampler containing four nominal 2-inch diameter, 4-inch long brass liners. The sampler is hydraulically pushed a maximum of 12 inches.	Dense	31 to 50	
		Very Dense	Greater than 50	
ST	Shelby Tube sample: Hydraulically-pushed, 3-inch diameter, thin-walled tube used for obtaining undisturbed soil samples.			
CME	CME 3-inch diameter continuous soil sampling system.	The shear strengths of silts and clays (fine-grained soils having more than 50 percent passing the #200 sieve) are directly related to the torvane reading (TV) and may be taken to be equal to one half of the unconfined compressive strength (Qu) of the soil. Furthermore, the pocket penetrometer reading (PP) approximates Qu which is related to consistency and manual methods as indicated in the following table:		
PS	Nominal 3-inch diameter Shelby tube piston sampler.			
D	Disturbed sample or auger cuttings			
NX	NX-size (2.155-inch diameter) rock core sample obtained using a diamond bit and recirculating water (See RQD below).			
PP	Pocket Penetrometer measurement indicative of soil unconfined compressive strength (ksf).			
TV	Torvane measurement of soil shear strength (tsf).	<b>CONSISTENCY</b>	<b>UNCONFINED COMPRESSIVE STRENGTH (ksf)</b>	<b>MANUAL PROCEDURE</b>
W %	As-received water content (percent)	Very Soft	< 0.5	Extrudes between fingers
LL	Liquid Limit	Soft	> 0.5 to 1	Molded by slight pressure
PL	Plastic Limit	Medium Stiff	> 1 to 2	Molded by strong pressure
USC	Unified Soil Classification	Stiff	>2 to 4	Indented by thumb
Qu	Unconfined compressive strength (ksf).	Very Stiff	> 4 to 8	Indented by thumbnail
RQD	Rock Quality Designation: The sum of the lengths of intact core pieces 4 or more inches (10 cm) in length, measured along the center line of the core, and expressed as a percentage of the length cored.	Hard	> 8	Difficult to indent
REC	Recovery: The length of recovered soil or rock sample expressed as a percentage of the sample length or depth cored.	<b>Minor Soil Constituent Terms and Definitions</b>		
▽	Point of groundwater entry.	Trace	Less than 5 percent	
▽	Stabilized groundwater level at some time after drilling.	Few	Between 5 and 10 percent	
<b>SAMPLING RESISTANCE</b>		Little	Between 10 and 25 percent	
P	Sampler pushed by hydraulic system.	Some	Between 25 and 50 percent	
3 6 9	Numbers indicate the number of blows from a 140-pound hammer falling freely for 30 inches required to drive the SPT sampler 6 inches. The SPT test result, N-value, or blow count, is the number of blows required to drive the sampler the last 12 inches. The N value for this example is 15.	<b>Coarse Grain Descriptors</b>		
50/2"	The split-spoon sampler was driven 2 inches by 50 blows; the Standard Penetration Resistance, or N-value, is set at 100.	Boulder	> 12 inches	
<b>ABBREVIATIONS USED</b>		Cobble	3 inches to 12 inches	
HSA	Hollow-Stem Auger	Coarse Gravel	3 inches to 3/4 inches	
SSA	Solid-Stem Auger	Fine Gravel	3/4 inches to #4 sieve	
ATD	At the time of drilling	The Graphical Key to Boring Logs shows the graphical symbols used on boring logs and generalized, geologic cross-sections of selected boring logs. The basic Unified Soil Classification System (USCS) designations are used for soils. The basic letter types are as follows: G - Gravels, S - Sands, M - Silts (M comes from the Swedish word mo for rock flour), W - Well graded, P - Poorly graded, C - Clay, H - High Plastic (fat), and L - Low Plastic (lean). Dual classification designations show the primary soil type throughout the graphic column, and the secondary soil type appears in the right half of the column. CL-CH, SP-GP, and GP-SP are examples.		
AD	After Drilling			
NATD	None at Time of Drilling			
DWL	Drill Water Loss			
		<b>TERM</b>	<b>MOISTURE CONDITION</b>	
		Dry	Water content is less than the plastic limit; dry to the touch	
		Moist	Water content is greater than the plastic limit, but the soil may be damp but no visible water	
		Wet	Soil exhibits free water or is obviously saturated.	

## GRAPHICAL KEY TO BORING LOGS

SOIL TYPE	GRAPHICAL SYMBOLS				
<b>GRAVELS</b>	Well-Graded		Poorly-Graded		
	 GW	 GP-SP	 GP	 GM	 GC
	 GW-GM	 GW-GC	 GP-GM	 GP-GC	 GC-GM
<b>SANDS</b>	Well-Graded		Poorly-Graded		
	 SW	 SP-GP	 SP	 SM	 SC
	 SW-SM	 SW-SC	 SP-SM	 SP-SC	 SC-SM
<b>SILTS and CLAYS</b>	Silts		Clays		
	 ML	 MH	 CL	 CH	 CL-ML
<b>SPECIAL SYMBOLS</b>	 CL w/Sand	 CH w/Sand	 Low Plastic Till	 High Plastic Till	 Loess
<b>ORGANIC SOILS</b>	Organic Silts		Organic Clays		
	 OL	 OH	 OL	 OH	 Peat
<b>MISCELLANEOUS</b>	 Asphalt	 Concrete	 Topsoil	 Fill	 Void
<b>IGNEOUS ROCKS</b>	 Granite	 Breccia	 Basalt	 Lava	 Tuff
<b>METAMORPHIC ROCKS</b>	 Quartzite	 Gneiss	 Schist	 Soapstone	 Marble
<b>SEDIMENTARY ROCKS</b>	 Limestone	 Dolomite	 Shale	 Sandstone	 Marl
	 Coal	 Conglomerate	 Siltstone	 Claystone	 Chalk
<b>MODIFIERS</b>	 Weathered	 Calcareous	 Cemented	 Caliche	 Chert
	<p>These symbols may be overlaid on basic symbols to form new symbols. The fill symbol (see Miscellaneous above) may replace the right half of any primary (single-style) soil symbol to differentiate between fill types. The CL and CH symbols can be combined to represent medium plastic clays.</p>				
<b>DRILLING METHODS</b>	 Solid-Stem Auger	 Hollow-Stem Auger	 Tri-Cone/Mud-Rotary	 NX Rock Core	 Rock Drilling

Date(s) Drilled: 08/31/2015 12:00 AM to 08/31/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 61.5 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 495.58 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1315650.768 E 2323895.167 (ft NAD83)	Groundwater Level(s): 41 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)	Graphic Symbol										
495	0					EMBANKMENT FILL: Dense, brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, dry									
490	5	1		100			7.2	7.8							
485	10	1	10 16 25	94		becoming with few medium grained sand	5.8	9.2							
480	15	2		56		becoming with little medium grained sand	9.4	9.7							
475	20	2	19 26 33	100		becoming very dense with few medium grained sand	9.8	11.9							
470	25	3		94		ALLUVIAL FOUNDATION: Dense to medium dense, brown and dark brown, silty SAND (SM), fine grained with few medium grained, dry	9.6	20.4							
30	30														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:03 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-1C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
465	30	3	13 13 17	100											
460	35	4		100		ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with little medium grained and trace fines, wet									
455	40	4	3 5 5	89				3.4							
450	45	5	3 5 11	100		becoming medium dense									
445	50	6	3 3 8	89		ALLUVIAL FOUNDATION: Medium dense, brown, silty SAND (SM), fine grained, wet									
440	55	7	4 6 9	100		becoming with little medium grained sand									
435	60	8	3 8 11	100		ALLUVIAL FOUNDATION: Medium dense, brown, poorly graded SAND (SP), medium grained with some fine grained and few coarse grained, few fines, and little fine gravel, wet		5.7							
	61.5					increasing grain size with depth									
	65					End of Boring at 61.5 ft									

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:03 AM

Date(s) Drilled: 09/01/2015 12:00 AM to 09/01/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 40.0 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 470.014 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1315557.387 E 2323962.772 (ft NAD83)	Groundwater Level(s): 18.5 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
470	0						ALLUVIAL FOUNDATION: Medium dense, dark brown, silty SAND (SM), fine grained with few medium grained, dry								
465	5	1	688	94			becoming very loose, with trace medium grained sand, moist	9.6	25.3						
460	10	2	222	100											
455	15	3	335	94			ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with little medium grained and trace fines, moist	20.5	2.0						
450	20	4	122	100			becoming very loose, wet, with some medium grained sand and few fines								
445	25	5	122	67					6.3						Add drilling mud to augers
30	30	6	244	67			becoming loose, poorly graded sand with gravel, trace fines								

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:09 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-1T**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS	
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)												
440	30					[Dotted Pattern]										
435	35	7	4 5 7	89	becoming medium dense											4.8
430	40	8	6 9 9	89	becoming medium grained with some fine grained, trace coarse grained, trace fine gravel, and trace fines											5.0
					End of Boring at 40 ft											
425	45															
420	50															
415	55															
410	60															
405	65															

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:09 AM



Date(s) Drilled: 09/02/2015 12:00 AM to 09/02/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 56.0 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 495.879 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1317139.899 E 2324566.088 (ft NAD83)	Groundwater Level(s): Not observed prior to introduction of drilling fluid	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)	Graphic Symbol										
495	0					EMBANKMENT FILL: Dense, brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, dry									
	5	1		83			6.5	7.4							
490															
	10	1	8 20 20	100			7.6								
485															
	15	2		83		LOWER STRENGTH EMBANKMENT FILL: Loose, brown, poorly graded SAND (SP), fine grained with few medium grained and trace fines, dry	5.3	4.6							
480															
	20	2	4 4 4	100		ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with few medium grained and trace fines, dry									Stratified in lifts
475															
	25	3		100			6.4	2.8							
470															
	30	3	4 4 4	94											

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:14 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-2C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
465	30														
		4		100		becoming with trace medium grained sand	5.2	3.3							
460	35														
		4	5 8 8	89		becoming medium dense, light brown, with little medium grained sand and trace fine gravel		4.6							Add drilling mud to augers
455	40														
		5	5 6 6	78		becoming light brown									
450	45														
		6	4 5 6	83		ALLUVIAL FOUNDATION: Medium dense, light brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, wet		8.0							
445	50														
		7	3 7 8	89											
440	55	8	2 3	67		ALLUVIAL FOUNDATION: Medium dense, brown, poorly graded SAND (SP), fine grained with trace medium grained and trace fines		4.5							Auger bound up in boring at 55 ft
						End of Boring at 56 ft									
435	60														
430	65														

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:14 AM

Date(s) Drilled: 09/01/2015 12:00 AM to 09/01/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 42.5 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 476.808 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1317122.482 E 2324639.284 (ft NAD83)	Groundwater Level(s): Not observed prior to introduction of drilling fluid	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)	Graphic Symbol										
0	0.0						ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND with silt (SP-SM), fine grained with few medium grained, dry								
475															
470	1	2 2 3	100					6.3							
467.8															
465	2	2 4 4	100				ALLUVIAL FOUNDATION: Loose, brown, clayey SAND (SC), fine grained with few medium grained, moist		22.0						
464.8															
460	3	2 4 4	100				ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with few medium grained and trace fines, dry								
455	4	2 2 3	94				becoming with little medium grained sand		2.0						Add drilling mud to augers
450	5	3 4 4	78				becoming with some medium grained sand, moist								
30															

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:20 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-2T**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
445	30	6	2 4 4	83	[Stippled Pattern]	becoming wet		4.8							
440	35	7	3 4 5	72											
435	40	8	2 3 4	67											becoming poorly graded sand with gravel, trace fines
						End of Boring at 42.5 ft									
430	45														
425	50														
420	55														
415	60														
65	65														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:20 AM

Date(s) Drilled: 09/02/2015 12:00 AM to 09/02/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 61.5 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 495.687 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1317142.772 E 2323859.689 (ft NAD83)	Groundwater Level(s): Not observed prior to introduction of drilling fluid	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)											
495	0					EMBANKMENT FILL: Dense, dark brown, silty SAND (SM), fine grained with few medium grained, dry									
490	5	1		100			8.7	21.5							
485	10	1	12 20 24	100			7.8	19.4							
480	15	2		67		EMBANKMENT FILL: Dense, brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, dry	6.5	6.8							
475	20	2	14 16 17	100		interbedded dark brown fine grained with brown medium grained									
470	25	3		100		becoming reddish brown with few medium grained sand		10.7							
30	30														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:25 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-3C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
465	30	3	4 4 3	100		LOWER STRENGTH EMBANKMENT FILL: Loose, brown, poorly graded SAND (SP), fine grained with some medium grained and trace fines, moist									
460	35	4		100				3.7							
455	40	4	2 4 6	100		ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with some medium grained and trace fines, moist  increasing grain size									
450	45	5	6 10 12	78		ALLUVIAL FOUNDATION: Medium dense, brown, silty SAND (SM), some fine grained, some medium grained, trace coarse grained, trace fine gravel, wet		20.2							
445	50	6	4 6 8	89		ALLUVIAL FOUNDATION: Medium dense, brown, poorly graded SAND with silt (SP-SM), fine grained with some medium grained, trace coarse grained, and trace fines, wet									
440	55	7	4 8 10	89				5.4							
435	60	8	2 3 3	78		becoming loose									
65						End of Boring at 61.5 ft									

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:25 AM

Date(s) Drilled: 09/01/2015 12:00 AM to 09/01/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 40.0 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 495.379 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1316468.402 E 2323338.783 (ft NAD83)	Groundwater Level(s): Not observed prior to introduction of drilling fluid	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)											
495	0					EMBANKMENT FILL: Brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, dry									
490	5	1		100				5.2							
485	10	1	9 17 20	89		EMBANKMENT FILL: Dense, brown, silty SAND (SM), fine grained with few medium grained, dry		13.8							
480	15	2		100		EMBANKMENT FILL: Brown, poorly graded SAND with silt (SP-SM), fine grained with few medium grained, dry		11.2							
475	20	2	9 14 15	89		EMBANKMENT FILL: Medium dense, brown, mottled dark brown, silty SAND (SM), fine grained with few medium grained, dry		13.6							
470	25	3		100		EMBANKMENT FILL: Gray, mottled light reddish brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, dry		7.3							
	30	3	17 27 37	94		EMBANKMENT FILL: Very dense, brown, silty SAND (SM), fine grained with little medium grained, dry		12.9							

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:31 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-4C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
465	30														
		4		33		becoming dark brown with few medium grained sand		28.6	14	1					
460	35														
						ALLUVIAL FOUNDATION: Loose, light brown, poorly graded SAND with silt (SP-SM), fine to medium grained, moist, stratified as placed in lifts									
455	40	4	2 3 5	100		End of Boring at 40 ft									
450	45														
445	50														
440	55														
435	60														
	65														

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:31 AM



<b>Project: Dynegy</b>	<b>Log of Boring HAV-EB-5C</b>
Project Location: Havana Power Plant, Havana, IL	Sheet 1 of 2
Project Number: 60439304	

Date(s) Drilled: 09/04/2015 12:00 AM to 09/04/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 62.5 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 490.085 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1316095.545 E 2322227.332 (ft NAD83)	Groundwater Level(s): 46 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)	Graphic Symbol										
490	0					EMBANKMENT FILL: Very dense, reddish brown, poorly graded SAND with silt (SP-SM), fine grained with few medium grained	0.0								
485	5	1		89			9.1	10.1							
480	10	1	19 25 27	89		becoming moist with little medium grained sand and trace coarse grained sand	7.2	9.2							
475	15	2		67		becoming with some medium grained sand	7.0	6.4							
470	20	2	16 27 39	89											
465	25	3		89		becoming with little medium grained sand	8.0	5.8							
	30														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:36 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-5C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
460	30	3	3 4 4	100		becoming loose, dry									
						ALLUVIAL FOUNDATION: Loose to medium dense, brown, poorly graded SAND (SP), fine grained with little medium grained and trace fines, moist									
455	35	4	4 8 4	100											
450	40	4		83				0.8							
445	45	5	1 3 3	67		becoming wet		1.1						Add drilling mud to augers	
440	50	6	2 2 3	83		increasing grain size									
435	55	7	2 6 7	89		becoming medium grained sand with some fine grained sand, trace coarse grained sand, few fine gravel, trace coarse gravel, and trace fines		2.2							
430	60	8	4 6 7	78											
						End of Boring at 62.5 ft									
65															

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:36 AM

Date(s) Drilled: 09/03/2015 12:00 AM to 09/03/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 40.0 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 462.361 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1316129.918 E 2322124.964 (ft NAD83)	Groundwater Level(s): 18.5 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
462.4	0					ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND with silt (SP-SM), fine grained with trace medium grained, dry									
	5	1	3 4 4	100				8.0							
455.4						ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with some medium grained and trace fines, dry									
	10	2	2 3 3	100		trace fine gravel at 9.25 ft		4.6							
450.4						ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND with silt (SP-SM), fine grained with little medium grained, moist									
	15	3	2 3 2	94				5.8							
445.4						ALLUVIAL FOUNDATION: Very loose, brown, poorly graded SAND (SP), some fine grained, some medium grained, trace coarse grained, trace fines, trace fine gravel, wet									
	20	4	2 2 2	100				4.0							Add drilling mud to augers
	25	5	2 2 2	78											
435.4						ALLUVIAL FOUNDATION: Medium dense, brown, poorly graded SAND with silt (SP-SM), fine grained with few medium grained, wet									
	30	6	4 5 7	83				5.3							

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:41 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-5T**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
30															
430															
	35	7	2 3 5	78		ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND (SP), fine grained with some medium grained, trace coarse grained, few fine gravel, and trace fines, wet									
	40	8	3 3 6	72											
	40	End of Boring at 40 ft													
420															
45															
415															
50															
410															
55															
405															
60															
400															
65															

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:41 AM

Date(s) Drilled: 09/03/2015 12:00 AM to 09/03/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 40.0 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 488.816 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1315472.242 E 2322011.383 (ft NAD83)	Groundwater Level(s): 33.5 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core ROD (%)	Recovery (%)											
488.8	0					EMBANKMENT FILL: Dark brown, mottled gray, clayey SAND (SC), some fine grained, trace medium and coarse grained, and few fine gravel, dry									
485	5	1		100			12.3	43.1	25	11					
481.8						EMBANKMENT FILL: Loose, brown, silty SAND (SM), fine grained with trace medium and coarse grained sand and trace fine gravel									
480	10	1	4 5 5	89				36.3	14	1					
476.8						EMBANKMENT FILL: Dense, brown, poorly graded SAND with silt (SP-SM), fine grained with trace medium grained, dry									
475	15	2		100			9.3	10.0							
470	20	2	11 13 19	89											
465	25	3		50		becoming brown and dark brown with few medium grained sand	12.1	6.4							
461.8						ALLUVIAL FOUNDATION: Medium dense, dark brown, silty, clayey SAND (SC-SM), fine grained with trace medium grained, dry									
460	30	3	9 11 11	100				37.7	18	5					

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:47 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-6C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
30															
455	35	4		100		ALLUVIAL FOUNDATION: Very loose, brown, poorly graded SAND (SP), fine grained with little medium grained and trace fines, wet		3.4							
450	40	4	2 2 2	100		becoming moist with trace medium grained sand		4.1							
						End of Boring at 40 ft									
445	45														
440	50														
435	55														
430	60														
425	65														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:47 AM

Date(s) Drilled: 09/03/2015 12:00 AM to 09/03/2015 12:00 AM	Logged By: Rick Horner	Checked By: JAA and BDL
Drilling Method: Hollow Stem Auger	Drill Bit Size/Type: Finger Bit	Borehole Depth: 42.5 ft
Drill Rig Type: ATV-CME 750	Drilling Contractor: Frontz	Surface Elevation: 489.253 ft NAVD88
Borehole Backfill: Cement bentonite grout	Sampling Method(s): Split Spoon/Shelby Tube	Hammer Data: Auto Hammer, 140 pound
Boring Location: N 1315618.981 E 2322377.352 (ft NAD83)	Groundwater Level(s): 26 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)	Graphic Symbol										
0	0					EMBANKMENT FILL: Brown, mottled dark brown and gray, silty SAND (SM), fine grained with trace medium grained, dry									
485	5	1		100				8.0	21.8						
480	10	1	3 3 3	89		becoming loose		4.6	17.8						
475	15	2		100		EMBANKMENT FILL: Loose, brown, poorly graded SAND with silt (SP-SM), fine grained with trace medium grained		7.9	11.7						
470	20	2	4 5 5	100		becoming moist		8.2	10.6						
465	25	3	5 13 21	100		ALLUVIAL FOUNDATION: Loose, brown, poorly graded SAND with silt (SP-SM), fine grained with trace medium grained, moist									
460	30					becoming dense, wet lense of stiff, dry, dark brown, low plastic silty clay									Lost sample in tube, drove split spoon in place

Report: GEO\_SOIL\_HAV; File G:\GINT\FILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:52 AM

**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-7C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
30		4	467	83	[Stippled pattern]	becoming medium dense, with few medium grained sand		10.0						Add drilling mud to augers	
455	35	5	679	89											
450	40	6	6811	83			becoming with little medium grained sand, trace coarse grained sand, and trace fine gravel		8.7						
445	45						End of Boring at 42.5 ft								
440	50														
435	55														
430	60														
425	65														

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA DYNEGY\_2015.GPJ; 2/26/2016 9:50:52 AM



**Project: Dynegy**  
 Project Location: Havana Power Plant, Havana, IL  
 Project Number: 60439304

**Log of Boring HAV-EB-8C**  
 Sheet 1 of 2

Date(s) Drilled	08/31/2015 12:00 AM to 08/31/2015 12:00 AM	Logged By	Rick Horner	Checked By	JAA and BDL
Drilling Method	Hollow Stem Auger	Drill Bit Size/Type	Finger Bit	Borehole Depth	40.0 ft
Drill Rig Type	ATV-CME 750	Drilling Contractor	Frontz	Surface Elevation	488.839 ft NAVD88
Borehole Backfill	Cement bentonite grout	Sampling Method(s)	Split Spoon/Shelby Tube	Hammer Data	Auto Hammer, 140 pound
Boring Location	N 1315276.961 E 2322410.504 (ft NAD83)		Groundwater Level(s)	38.5 ft ATD	

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)	Graphic Symbol										
488.8	0					EMBANKMENT FILL: Brown, silty SAND (SM), fine grained with few medium grained and trace fine gravel									
485	5	1				EMBANKMENT FILL: Dark gray sandy CLAY (CL), with trace fine gravel and few coarse gravel	17.4	24.7	30	15					
480	10	1	20 21	72		EMBANKMENT FILL: Dense, brown, silty SAND (SM), fine grained with trace medium grained	12.8	60.8							
475	15	2		89		EMBANKMENT FILL: Brown, poorly graded SAND with silt (SP-SM), fine grained with trace medium grained	12.2	17.6							
470	20	2	8 9 8	72		EMBANKMENT FILL: Medium dense, brown, silty SAND (SM), fine grained with trace medium grained	9.1	19.0							
465	25	3		67		ALLUVIAL FOUNDATION: Brown, poorly graded SAND with silt (SP-SM), fine grained with few medium grained	6.9	6.7							
460	30	3	5 8 8	100		ALLUVIAL FOUNDATION: Medium dense, dark brown, silty SAND (SM), fine grained with trace medium grained	9.5	27.7							
						becoming reddish brown to brown, slight increase in grain size	11.5	8.5							

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:57 AM



**Project: Dynegy**

Project Location: Havana Power Plant, Havana, IL

Project Number: 60439304

**Log of Boring HAV-EB-8C**

Sheet 2 of 2

Elevation (feet)	Depth (feet)	SAMPLES				Graphic Symbol	MATERIAL DESCRIPTION	Natural Moisture Content (%)	Percent Passing No. 200 Sieve (%)	Liquid Limit	Plasticity Index	Pocket Pen. Su (ksf)	Torvane Su (ksf)	TXUU (ksf)	REMARKS
		Type Number	Sampling Resist. OR Core RQD (%)	Recovery (%)											
30															
455	35	4		100	[Stippled Pattern]	ALLUVIAL FOUNDATION: Medium dense, brown, poorly graded SAND (SP), fine grained with few medium grained and trace fines		3.1							
450	40	4	5 8 11	89		becoming wet, with some medium and fine grained sand, few coarse grained sand, trace fine gravel, and trace fines		3.1							
445						End of Boring at 40 ft									
440	50														
435	55														
430	60														
425															
65															

Report: GEO\_SOIL\_HAV; File G:\GINTFILES\PROJECTS\60439304 HAVANA.DYNEGY\_2015.GPJ; 2/26/2016 9:50:57 AM